



FDNY

BUREAU OF FIRE PREVENTION**9 Metro Tech Center, 3rd Floor****Brooklyn, NY, 11201**

To: Tim Kelley

From : New York City Fire Department

Date Aug 4, 2026

Record ID: 2026-TMCOAP-004434-CERT



Premises Address: City-Wide

BIN

Application Type: Certificate of Approval

Result: Certificate of Approval

CERTIFICATE OF APPROVAL # 5988

THIS CERTIFICATE IS REVOCABLE, NOT TRANSFERABLE

AND EXPIRES ON August 3, 2029

By order of Fire Commissioner and pursuant to Section 112 of the New York City Fire Code, the following equipment or material may be acceptable for use provided the conditions outlined below are in full compliance.

Manufacturer: Giles Enterprises, Inc.

Address: 2750 Gunter Park Drive West, Montgomery, AL 36109

Product: GXF Series prefabricated ventless/ductless commercial kitchen hoods and grease filter with built-in fryer and grease filter for use in the NYC Department of Buildings (DOB) approved commercial kitchens at or above grade level.

Model Number: GXF-S, GXF-F; may be followed by additional suffixes

Pertinent Code : New York City Fire Code Section 901.4.5

Prescribed Tests: UL710B, UL300

Laboratory: Underwriters Laboratories, Inc.

Report: File #:E143926 Vol. 1 Sec. 4 Issued: 12-27-2013 Revised: 02-27-2026



FDNY

BUREAU OF FIRE PREVENTION**9 Metro Tech Center, 3rd Floor****Brooklyn, NY, 11201**

Description: The products are field wired or cord connected, countertop supported fryer with integral ductless hood. It is provided with an Amerex 70 oz. fire suppression system and filters to limit the emissions of grease laden vapors. The model GXF-F is identical to model GXF-S except overall electrical ratings and the model GXF-F dispenses product out the front of the unit instead of the side of the unit.

Conditions of Approval

1. The ventless/ductless hoods shall ONLY be used within NYC Department of Buildings (DOB) approved commercial kitchens, plans for which shall be docketed (stamped, dated and numbered) by the New York City Department of Buildings and subject to the following restrictions:

- a. Ventless hoods shall not be installed in the basement or cellar of any building.
- b. Ventless hoods shall not be installed in any non-fireproof buildings.
- c. Ventless hoods shall not be installed in any unsprinklered buildings.
- d. Ventless hoods shall not be installed in any open spaces such as shopping malls.

NOTE: For locations that do not meet of the above criteria, a request for special consideration may be submitted for a site-specific approval of the use of light duty cooking /food warming operation within the City of New York.

2. Prior to installation of the above-referenced ductless/ventless hood, plans shall be filed with and approved by New York City Department of Buildings (DOB). A copy of DOB approved plans or other DOB documentation for such approval shall be transmitted to the New York City Fire Department when requested.

3. Prior to installation of the the fire extinguishing system, plans shall be filed with the New York City Fire Department for review and approval. Pre-engineered non-water fire extinguishing system shall be of a type for which a Certificate of Approval has been issued by the New York City Fire Department.

4. Installation, use and maintenance (including cleaning) of the above-referenced products shall comply with all applicable requirements of the New York City Fire Code, the New York City Construction Codes (including the Building Code and the Mechanical Code), the New York City Electrical Code, and the rules.

5. Listing requirements and the manufacturer's installation, operation and maintenance requirements shall be complied with.

6. The above-referenced products shall be inspected, cleaned and replaced if necessary by a qualified person holding a Fire Department Certificate of Fitness, as applicable. A record of such inspection and cleaning shall be kept on the premises for inspection.

7. All installations shall be subject to inspection by representatives of the Fire Department which may result in additional requirements being imposed. The Fire Department may make periodic inspections of the above-referenced products without warning. These audit inspections will be solely at the discretion of the Fire Department.

8. The Fire Department's condition of approval shall be provided to all New York City buyers, uses, and installers.

9. Manufacturer shall ensure there are sufficient qualified contractors on the FDNY approved list of approved companies to maintain the product.



FDNY

BUREAU OF FIRE PREVENTION

9 Metro Tech Center, 3rd Floor

Brooklyn, NY, 11201

10. Certificate of Approval number shall be plainly and permanently stamped or otherwise affixed upon each product by the manufacturer or the local representative of the manufacturer.
11. The equipment's technology does not violate any patent, trade name, trade secret or other intellectual right.
12. Only parts and components that the hood is listed with and are included in the manufacturer's manual shall be used with the system. No other parts or components shall be retrofitted to the hood.
13. Fire Department Certificate of Approval does not constitute an endorsement or recommendation of your product by the Fire Department, but is a certification that your product is acceptable as of the date of issuance.
14. The Fire Department may withdraw this approval at any time in the event there is a reasonable doubt that the product does not operate or perform as required by code, the conditions of this resolution or as represented in your application.
15. Any end user who fails to comply with the condition as outlined in this approval will be subject to enforcement action.

Any change in occupant's name or ownership, product name, product design, material of construction or model number of any product included on this certificate must be immediately reported to this Department in writing.

KC:JN

By Order of,
Chief of Fire Prevention