

DDO	MEN	& TRI	LCT	EDC	INCE	1050
PKU	VEN	67 1 151	J 3 I	ED 3	INCE	ISON

Project Name/No:		Item No:
Ouantity:	SIS#:	AIA/CSI#:

## Multi-Appliance Ventless Recirculating Hood FSH-6



2 Configuration Options:
Ceiling Suspended
or
72" Floor-Stand

- 72" wide, Type-1, Ventless Recirculating Hood for *electric* fryers, griddles, broilers, ranges & ovens.
- Free-standing on 72" tall floor stand to maximize usable hood width (standard) -or- ceiling suspended version w/side skirts (optional).
- No venting to outside required ... generally, can be installed where conventional ventilation hood solutions are prohibited or too costly for the budget ... <u>vented solutions should always be the first alternatives</u>.
- Durable stainless steel construction.
- Proven 4-stage air cleaning technology meets requirements for grease laden vapor removal for a variety of commercial cooking appliances.
   Listed to UL-YZCT (\*7 Earagh), complies with ANSI/UL-710B.
- Listed for the Ansul® R102 Wet Chemical Fire Suppression System. Hood is factory pre-plumbed, with piping, plenum nozzles, detector link brackets & cable conduit stubbed out ready for connection. Does not include appliance drop-down hozzles. Customer supplies system, field installation rinal set-up & commissioning ... must be supplied & installed by an authorized Ansul® service company (not included with purchase).

#### **Design Features**

## Ventless Hood System 4-Stage Air Cleaning:

- [1] Two (2) stainless steel baffle filters (not seen) trap large grease particulate.
- [2] Two (2) disposable pre-filters trap smaller particulate and help to remove moisture
- [3] Two (2) long-life, reflewable
  Electronic Air Cleaner (EAC)
  collector cells electrostalically
  capture & collect fine particulate on collecti
- [4] Two (2) disposable charcoal filters help to control cooking a omas in the exhausted air.

#### Standard Features

Built in appliance interlock relay

- posh-ro-start power switch ... must be pressed after power interruptions to restart hood & provide power to cooking appliances underneath ... required by code in some jurisdictions.
- Complete filter set included.
  - Choose 72" tall full-skirt floor stand configuration.
- Built-in filter cleaning timer feature ... helps user maintain optimum hood performance.

#### Limitations: HOOD APPROVED ONLY FOR USE WITH ELECTRICALLY HEATED APPLIANCES ... NO GAS

Appliance	Max. Input	Max. Cooking	Max. Shortening Max. Cooking Area	
Type	Power (kW)	Temp.	Capacity	Max. Cooking Area
Envors	40 (Total) or	350°F [177°C]	160 lbs [72 kg] [Total]	380 sq in [0.25 sq m] single fryer
Fryers	20 (per Fryer)	30 F [1// C]	80 lbs [36 kg] [per Fryer]	760 sq in [0.49 sq m] any combination
Ovens	55	500°F [260°C]	N/A	68-1/2"W x 42"D [1829mm x 1067mm]
Griddles	25	400°F [204°C]	N/A	68-1/2"W x 26"D [1524mm x 660mm]
Ranges	Max. 8 Burners	400°F [204°C]	N/A	68-1/2"W x 26"D [1524mm x 660mm]
Broilers (Vert/Horiz)	25	500°F [260°C]	N/A	68-1/2"[1524mm] W x 26"[660mm] D 42" max height (appl top to hood btm)

#### IMPORTANT INFORMATION!!

Orders for GILES Recirculating/Ventless Hood systems will not be accepted until Giles verifies ... 1). the Purchaser has received all necessary approvals from local authorities ... 2). the cooking appliances to be used are within the hood's listing limitations ... 3). the Purchaser is aware of specific requirements & limitations with which installation must comply, as stated in the GFSE Recirculating/Ventless Hood Approval Letter (HAL). The Approval Letter must be fully completed & submitted, along with any other requested information, and must be approved by Giles Technical Services personnel before an order will be accepted.

The HAL document is available for review & download by clicking here: HOOD APPROVAL LETTER

## **Ventless Hood**


## **Model FSH-6**

Project Name	e/No:	Item No:	
Ouantity:	SIS#:	AIA/CSI#:	

#### **Ceiling Suspended**

# 

**Floor Stand** 



Inches [mm]

#### **Specifications**

Construction: 18 & 20-Ga high-grade stainless steel sheet metal ... formed & welder

Dimensions: *	Includes Side Skir	ts
Width	Depth	Height
vviatii		Suspender Floor Stand
72-11/16"	49-5/8"	*74" 117-3/16"
[1846 mm]	[1260 mm]	[1880 mm] [2977 mm]

Elecated Specification 400 Only						
Voltage	Phase	Amps				
208-240 60	1	8				
220 50	1	8				
Power cord NOT provided; field wiring required.						

### Neutral line required for lights.

#### **Hood Mechanical Specifications**

Hood Exhaust - 840 to 940\_EFM
Sound Level (approx.) - 75 dB

Min. Clearance -

14" [336 mm] (Exhaust to Ceiling

Crated Wt. Suspended: 788 lbs [357 kg]
Floor Stand: 925 lbs [420 kg]

Cube: 56"[1422mm] x 86"[2184mm] x 53"[1346mm]=147.7 cu ft [4.2 cu m]

ions: Freight Class 125

Accessory Items Included: (2) Baffle Filters • (2) Pre-Filters • (2) EAC Filter Cells • (2) Charcoal Filters • (1) Tube Sealing Silicone • (1) Can, Spray Foam EAC Cell Cleaner (sample)

Shipping

#### **IMPORTANT!** Before Ordering

- Purchaser must obtain, read, complete & submit approval a <u>Giles Hood Approval Letter (HAL)</u>. By signing a <u>HAL</u>, the purchaser affirms that
  installation site has been assessed & it is completed with the minimum requirements, stated therein, regarding kitchen size, ceiling height, fresh
  outside air supply, room air exchange are, exhaus ventilation, clearances, etc.
- Verify that cooking appliances to be used rewithin limitations shown in the table on first page ... contact factory to resolve any questions.
- Does available electrical power meet hood specifications?

#### **How To Specify**

### Determine Hood Item Number:

1	Item Number	Voltage	Hz	Ph	Configuration	
	71463	208-240	60	1	Floor Stand	
	71865	220-230	50	1	(Standard)	
	78973	208-240	60	1	Ceiling Suspended	
	70535	220-230	50	1	(Optional)	

#### 2 Extra Accessories (sold separately) Specify quantity:

1	Qty	Description	Part Number
		Pre-Filter	91707
		EAC Filter (Left-side)	20521
		EAC Filter (Right-side)	20520
		Charcoal Filter	32056
		EAC Foaming Spray Cleaner (12-ct Case, 20-oz can)	41510



Specifications and/or product design are subject to change without notice. Such revisions do not entitle the buyer to corresponding changes, improvements, additions or replacements for previously purchased equipment.